

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 164Dated: 20/03/2025

It is certified that an inspection team headed by Mr. B. K. Sagar
(Name of Officers with designation) from Public Health Engineering Department
PHED inspected the **WONDER PUBLIC CENTRAL SCHOOL, WARD NO. 12 MACHHARIYA ROAD MIHONA, DIST. -**
BHIND, MP on 18/03/2025 and on the basis of Water Test Report (Attached) bearing no. 164
dated 19/03/2025 of PHED Water testing Laboratory, Lahar (PHED Lab)
certified that the **WONDER PUBLIC CENTRAL SCHOOL, WARD NO. 12 MACHHARIYA ROAD MIHONA, DIST.- BHIND,**
MP has safe drinking water facilities for the students and members of staff of the institution. School is also
maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till 19/03/2026 (one year)

Signature with seal

:-

Assistant Engineer
Public Health Engineering
Sub Dn. Lahar Dist. Bhind (M.P.)

Name

:-

Mr. B. K. Sagar

Designation

:-

Assistant Engineer

Name & address of the office/Department :-

PHED, Lahar

To,

WONDER PUBLIC CENTRAL SCHOOL,
WARD NO. 12 MACHHARIYA ROAD MIHONA, DIST.- BHIND, MP
(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies

Asst. P.H.E. Dayhliya

सांचव

Principal
Principal

Wonder Public Central School
Mihona Dist. Bhind (M.P.)

Sub Divisional Water Testing Laboratory PHE, Lahar Distt - Bhind (M.P)

1. Sample From
2. Particulars Of Sample
3. Date of Collection
4. Date of Analysis

Atal Sharma

wonder public central school mihona

18/03/2025

19/03/2025

			As Per BIS 10500-2012 For Drinking Water		RESULT		
S.no.	Characteristics	Unit	Requirement (Desirable Limit)	Permissible Limit in The absence of Alternate Source			
PHYSICAL					Sample-1	Sample-2	Sample-3
1	Turbidity	NTU	1.0	5.0	2.5		
2	Colour	Cobalt	5	15	Nil		
3	Taste & Odour		Unobjectionable	Unobjectionable	odourless		
4	Temperature	C					
CHEMICAL							
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	7.5		
6	Alkalinity	Mg/L	200	600	248		
7	Chlorides(as CL)	Mg/L	250	1000	62		
8	Nitrate as No3	Mg/L	45	45	8.3		
9	Total Hardness by standard E.D.T.A. Solution	Mg/L	200	600	288		
10	Calcium as Ca	Mg/L	75	200	35		
11	Magnesium as Mg	Mg/L	30	100	38		
12	Iron	Mg/L	0.3	0.3	0.11		
13	Free Chlorine	Mg/L	0.2	1	Nil		
14	T.D.S.	Mg/L	500	2000	600		
15	Fluoride	Mg/L	1.0	1.5	0.17		
16	Bactological Feacual Coliform	Per 100 ml	0	0	Nil		

ASHUTOSH UPADHYAY
CHEMIST
PHED Sub Division Lahar Distt. Bhind

Ashutosh Upadhyay
सचिव

Singh
Principal
Wonder Public Central School
Mihona Dist. Bhind (M.P)

Assistant Engineer
Public Health Engineering
Sub Dn. Lahar Distt. Bhind (M.P)

स्व. पीछित श्री मंगलीप्रसाद दौडलिया महिला एवं
बाल कल्याण शिक्षा प्रसार एवं समाज कल्याण समिति